



सोलापूर महानगरपालिका, सोलापूर
अग्निशमन व आणीबाणी सेवा

रविवार पेठ, मुख्य अग्निशमक केंद्र, सोलापूर - ४१३००५. फोन : ०२१७-२७४०३६४ / १०१
Email : solapurfirebrigade@gmail.com



संदर्भ : जा. क. अ.शा.द./१५५ :: Renewal certificate :: दिनांक : २२/४/२०२५

To,
The President
KLE Society
KLE English Medium School
Majrewadi, Jule Solapur,
Solapur

Subject : Renewal of fire brigade regarding obtaining NOC certificate.
Reference : Your reference letter, dated 21/04/2025.

Sir,

With reference to the above subject, you have submitted the request form to this office for getting renewal certificate of fire brigade for KLE English Medium School.

In this connection at the time of inspection regarding fire safety at place, it was found that the fire fighting materials and equipments are in good running condition. Therefore, renewal certificate of fire brigade is being issued for the year 2025-26 (end of March-2026) for the said KLE English Medium School.

- Periodic testing and refilling of fire extinguishers.
- The security guards and staff appointed at the said place should be trained in handling the above systems and equipment (fire extinguishers).
- Maintenance and care of fire extinguishers should be done on regular basis.
- All electrical wiring and circuit breakers etc. should be inspected from time to time by the concerned expert and his report should be submitted to this office.
- **It will be your responsibility to submit a certificate (in B Form) to the office twice a year (January and July) from a registered license holder firm from the Government of Maharashtra regarding the fire fighting system installed in the said building and that it is working properly.**

The said certificate is being issued at the end of (March 2026) subject to the condition of obtaining all other government licenses required for KLE English Medium School. The said certificate has been inspected only from the point of view of fire safety. (The Fire Extinguishers and other Fire protection systems installed by you in the premises shall be well maintained & shall be kept in tip top working condition at all the time. If the said system is not maintained, retrenched this NOC will stand cancelled without any notice & you will be fully responsible to loss of life or property if any which may please be noted.)

Date :- 22/04/2025




Rakesh Salunke

The Chief Fire Officer,
Solapur Municipal Corporation, Solapur